

LEGEND

- ⊕ FIXTURE - CEILING
- ⊕ FIXTURE - WALL MOUNTED
- ⊕ RECESSED CAN
- ⊕ MONO POINT/LOW EFF. SPOT
- TRACK LIGHTING
- FLUORESCENT
- ⊕ STEP LIGHT
- ⊕ POOL LIGHT
- ⊕ FIXTURE - LANDSCAPE
- ⊕ SWITCH
- ⊕ SWITCH - THREE WAY
- ⊕ SWITCH - DIMMER
- ⊕ SWITCH - MOTION SENSOR W/ AUTO OFF
- ⊕ MOTION SENSOR - WALL MOUNT
- ⊕ MOTION SENSOR - CEILING MOUNT
- ⊕ 110V OUTLET - WALL
- ⊕ 110V OUTLET - FLOOR
- ⊕ 110V OUTLET - CEILING
- ⊕ 220V OUTLET
- ⊕ GAS
- ⊕ TV/CABLE
- ⊕ TELEPHONE (MULTI-LINE)
- ⊕ X = LINE
- ⊕ SMOKE DETECTOR
- ⊕ CEILING FAN
- ⊕ EXHAUST FAN
- ⊕ SUPPLY DUCT
- ⊕ HOSE BIB
- ⊕ SHOWER CONTROLS
- ⊕ SHOWER HEAD


NOTES

- GFI = GROUND FAULT INTERRUPT
- LV = LOW VOLTAGE
- P = PENDANT
- WP = WATER PROOF
- MS = MOTION SENSOR
- LS = LIGHT SENSOR

GENERAL NOTES

1. CONTRACTOR TO ORGANIZE A WALK-THROUGH WITH THE OWNER & ARCHITECT PRIOR TO LAYOUT OF ELECTRICAL DEVICES
2. CENTER LINE OF OUTLETS @ 12" A.F.F., TYP. U.O.N.
3. CENTER LINE OF SWITCHES @ 42" A.F.F., TYP. U.O.N.
4. TELEPHONE AND OTHER DEVICES TO ALIGN WITH ADJACENT DEVICES U.O.N.
5. FOR MOTION SENSORS:
 - a. ALL SENSOR LOCATIONS ARE APPROXIMATE. REFER TO MANUFACTURER'S INSTALLATION INSTRUCTIONS PRIOR TO INSTALLATION. IF PENDANT MOUNTED FIXTURES ARE PRESENT, LOCATION AND COVERAGE OF SENSORS SHOULD BE REVIEWED.
 - b. ULTRASONIC CEILING MOUNT SENSORS REQUIRE THEY BE LOCATED NO CLOSER THAN 6' TO AIR SUPPLY/RETURN REGISTERS.
 - c. CONTRACTOR IS RESPONSIBLE FOR PROPER SENSITIVITY AND THE TIME DELAY SETTINGS, VERIFICATION OF MANUFACTURER'S RECOMMENDED PLACEMENT, AND FIELD VERIFICATION OF CIRCUITS WITH RESPECT TO POWER PACK PLACEMENT.
 - d. CONTRACTOR IS RESPONSIBLE FOR FIELD VERIFICATION OF REQUIRED NUMBER OF POWER PACKS.
 - A. ONE POWER PACK IS REQUIRED FOR EACH CIRCUIT THAT IS TO BE CONTROLLED.
 - B. MAXIMUM NUMBER OF SENSORS THAT CAN BE WIRED IN PARALLEL TO A SINGLE POWER PACK IS DEPENDENT ON SENSOR MODEL (SEE INDIVIDUAL DATA SHEETS FOR mA CONSUMPTION).

1 ELECTRICAL FLOOR PLAN - UPPER LEVEL
 E2.2 SCALE: 1/4" = 1'-0"


ARKIN TILT ARCHITECTS
 Ecological
 Planning
 & Design
 1101 8th St.
 Suite 180
 Berkeley, CA 94710
 telephone
 510.528.9830
 facsimile
 510.528.0206
 e mail
 info@arkintilt.com
 website
 www.arkintilt.com

NEW RESIDENCE for
CINDY BICKERSTAFF & MARK HOLLER
 1871 MOUNT VEEDEE ROAD
 NAPA, CA 94558
 A.P.N. 34-110-47

ELECTRICAL PLAN
 UPPER LEVEL

DATE:	01.30.06
JOB:	BH
SCALE:	AS NOTED
DRAWN:	
SHEET:	E2.2